



CITY OF LAKE WORTH BEACH
WATER UTILITIES DEPARTMENT
301 COLLEGE STREET
LAKE WORTH BEACH, FL 33460
561.586.1708

To: Utility Customers
From City of Lake Worth Beach Water Utilities Department
Name E. morales
Title Lab. Tech.
Date of Notice 3/15/2020
Subject Rescission of Precautionary Boil Water Notice

The precautionary boil water notice is hereby rescinded as of 3/15/2020 for your area served by the City of Lake Worth Water Utilities potable water distribution system. The following action was taken to correct the problem:

2" Water Main Repaired at 1120 12th Ave South

The satisfactory completion of the bacteriological survey showed the water is safe to drink.

This notice affects 11 customers and includes the following addresses:

This notice affects 11 customers and includes the following addresses:

12th Ave S- 1120 Apt #5, 1106 Apt #8
South G Street- 1109, 1105 Apt #10
South F Street- 1102, 1106, 1110, 1114, 1116, 1120, 1124

Should you have any questions please contact the Water Systems Department at (561) 586-1719 or Water Treatment Plant at (561) 586-1710.

CC:
Water Utility Director
Executive to the City Manager
Water Plant Lab
City Hall Information

Utilities Customer Service
Utilities System Operations/Dispatch
Communications Specialist
Florida Department of Health – Palm Beach County